SRI BAALAMURUGAN BOREWELLS

4, gangamma Compound, Opp. Canara Bank Bus Stop, Bellary Main Road, Helbal Bangalore - 24
Mob : 9845020536, 9901920004

WORK REPORT

No.

Date :

Kogilu Layouts 1st Main 3rd Cross

S.No.	Particulars	Rft :	Water Yield	Remarks
1.	Size of The Borewell	165 mm		
2.	Total Deapth of The Borewell	984'		
3.	MS Casing Erected	147'		
4.	1st Water Source at the Deapth	297'		
5.	2nd Water Source at the Deapth	501'		
6.	3rd Water Source at the Deapth	710'		
7.	4th Water Source at the Deapth	920'		
8.	If any Silt, Boulders at the Deapth	—		
9.	Nature of Water	Sweet water		
10.	Moter Pump to be Used	15 HP 25 Stage		
11.	Any other Remarks	—		
12.	Total Yield of the Borewell	2'-3"		

Thanking You

Yours faithfully
For Sri Baalamurugan Borewells

GROUND WATER SURVEY REPORT

OPEN WELL/ BOREWELL
DATA OF SURVEY

a) Name of the Party : AEE, Byalarayanapura. Sub Division

b) Location of the Site : BBMP Ward No-3

c) Area of the land : KoGilu layout 1st Cross 3rd main.

INVESTIGATION REPORT

1) GEOLOGY OF THE AREA :

2) Recommended Site for drilling :

3) Total depth to be drilled : 900' to 1200'

4) Approx. casing pipe required : 100' to 150'

5) No. of water bearing Zones : —1—

6) No. of favourable spots marked : —1—

7) Qty. of water expected : 2" to 2 1/4"

8) Method of survey carried out : GEO

9) Remarks :

P.T.O. : Terms & Conditions

HYDROGEOLOGIST
(M.G. RAJASHEKHAR, M.Sc., DEG., F.G.S.)

BOREWELL SITE PLAN



Name of work :- Drilling of borewell & Rmft & motor arr
Dwarakanagara Extn. Srinivasapura Taluk Palanahalli
Alias Kattigenahalli Extn. in ward No-5

W.No. 5. ದೊಡ್ಡಗಲು ಅಡ್ಡಕ್ಕೆ 1.ಮೇನ್ 3ನೇ ಕ್ರಾಸ್. ಮೆಗಲಕುರ್

AE-05
ಸಹಾಯಕ ಅಭಿಯಂತರರು
ಬಿ.ಬಿ.ಎಂ.ಪಿ. ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

Assistant Executive Engineer
Byatarayanapura Sub Division
B.B.M.P. Bangalore

W. No. 5. ಕೆಂಗೇರಿಉಪನಗರ 1ನೇ ಮುಖ್ಯರಸ್ತೆಯ ಭಾಗದಲ್ಲಿ

ಸಹಾಯಕ ಅಭಿಯಂತರರು
ಬಿ.ಡಿ.ಎ.ಪಿ. ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

Assistant Executive Engineer
Vidarayanapura Sub Division
BMP Bangalore